



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

November 06, 2020

Joe Manzer
Mechanicville City School District
25 Kniskern Ave
Mechanicville, NY 12118

Work Order No: 201013039

TEL: (518) 664-5727

RE:

Elementary School

Dear Joe Manzer:

Adirondack Environmental Services, Inc received 98 samples on 10/13/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in black ink that reads "Tara Daniels".

ELAP#: 10709

Tara Daniels
Laboratory Director

CLIENT: Mechanicville City School District

Date: 06-Nov-20

Project:

Lab Order: 201013039

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers: ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-001 **Collection Date:** 10/7/2020
Client Sample ID: ES-101-F **Matrix:** DRINKING WATER

Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-002 **Collection Date:** 10/7/2020
Client Sample ID: ES-101-S **Matrix:** DRINKING WATER

Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 10/13/2020)

Lead **ND** 1.0 µg/L 1 10/20/2020 5:02:35 PM

Lab SampleID: 201013039-003 **Collection Date:** 10/7/2020
Client Sample ID: ES-102-F **Matrix:** DRINKING WATER

Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-004 **Collection Date:** 10/7/2020
Client Sample ID: ES-102-S **Matrix:** DRINKING WATER

Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 10/13/2020)

Lead **ND** 1.0 µg/L 1 10/20/2020 5:13:51 PM

Lab SampleID: 201013039-005 **Collection Date:** 10/7/2020
Client Sample ID: ES-103-F **Matrix:** DRINKING WATER

Analyses **Result** **RL Qual Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-006 **Collection Date:** 10/7/2020
Client Sample ID: ES-103-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:17:33 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-007 **Collection Date:** 10/7/2020
Client Sample ID: ES-104-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-008 **Collection Date:** 10/7/2020
Client Sample ID: ES-104-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:21:16 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-009 **Collection Date:** 10/7/2020
Client Sample ID: ES-105-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-010 **Collection Date:** 10/7/2020
Client Sample ID: ES-105-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:24:59 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-011 **Collection Date:** 10/7/2020
Client Sample ID: ES-106-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-012 **Collection Date:** 10/7/2020
Client Sample ID: ES-106-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 10/13/2020)

Lead 1.6 1.0 µg/L 1 10/20/2020 5:28:43 PM

Lab SampleID: 201013039-013 **Collection Date:** 10/7/2020
Client Sample ID: ES-1GP-F1 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-014 **Collection Date:** 10/7/2020
Client Sample ID: ES-1GP-F2 **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-015 **Collection Date:** 10/7/2020
Client Sample ID: ES-201-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-016 **Collection Date:** 10/7/2020
Client Sample ID: ES-201-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:47:23 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-017 **Collection Date:** 10/7/2020
Client Sample ID: ES-202-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-018 **Collection Date:** 10/7/2020
Client Sample ID: ES-202-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:51:08 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-019 **Collection Date:** 10/7/2020
Client Sample ID: ES-203-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-020 **Collection Date:** 10/7/2020
Client Sample ID: ES-203-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:54:53 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-021 **Collection Date:** 10/7/2020
Client Sample ID: ES-204-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-022 **Collection Date:** 10/7/2020
Client Sample ID: ES-204-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 5:58:38 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-023 **Collection Date:** 10/7/2020
Client Sample ID: ES-205-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	Out of Service			NA		10/7/2020
-------------	----------------	--	--	----	--	-----------

Lab SampleID: 201013039-024 **Collection Date:** 10/7/2020
Client Sample ID: ES-205-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 6:09:49 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-025 **Collection Date:** 10/7/2020
Client Sample ID: ES-206-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-026 **Collection Date:** 10/7/2020
Client Sample ID: ES-206-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 6:13:32 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-027 **Collection Date:** 10/7/2020
Client Sample ID: ES-2GP-F1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-028 **Collection Date:** 10/7/2020
Client Sample ID: ES-2GP-F2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-029 **Collection Date:** 10/7/2020
Client Sample ID: ES-301-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-030 **Collection Date:** 10/7/2020
Client Sample ID: ES-301-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	1.4	1.0		µg/L	1	10/20/2020 6:17:15 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-031 **Collection Date:** 10/7/2020
Client Sample ID: ES-302-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-032 **Collection Date:** 10/7/2020
Client Sample ID: ES-302-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 10/13/2020)

Lead **ND** 1.0 µg/L 1 10/20/2020 6:20:59 PM

Lab SampleID: 201013039-033 **Collection Date:** 10/7/2020
Client Sample ID: ES-303-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-034 **Collection Date:** 10/7/2020
Client Sample ID: ES-303-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 10/13/2020)

Lead **ND** 1.0 µg/L 1 10/20/2020 6:32:10 PM

Lab SampleID: 201013039-035 **Collection Date:** 10/7/2020
Client Sample ID: ES-304-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation **OutofService** NA 10/7/2020

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-036 **Collection Date:** 10/7/2020
Client Sample ID: ES-304-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 6:35:54 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-037 **Collection Date:** 10/7/2020
Client Sample ID: ES-305-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-038 **Collection Date:** 10/7/2020
Client Sample ID: ES-305-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 6:39:39 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-039 **Collection Date:** 10/7/2020
Client Sample ID: ES-306-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-040 **Collection Date:** 10/7/2020
Client Sample ID: ES-306-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 6:43:23 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-041 **Collection Date:** 10/7/2020
Client Sample ID: ES-402-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService	NA				10/7/2020
-------------	--------------	----	--	--	--	-----------

Lab SampleID: 201013039-042 **Collection Date:** 10/7/2020
Client Sample ID: ES-402-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 6:47:08 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-043 **Collection Date:** 10/7/2020
Client Sample ID: ES-403-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService	NA				10/7/2020
-------------	--------------	----	--	--	--	-----------

Lab SampleID: 201013039-044 **Collection Date:** 10/7/2020
Client Sample ID: ES-403-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 7:05:48 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-045 **Collection Date:** 10/7/2020
Client Sample ID: ES-404-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService	NA				10/7/2020
-------------	--------------	----	--	--	--	-----------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-046 **Collection Date:** 10/7/2020
Client Sample ID: ES-404-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 10/13/2020)
Lead **1.0** 1.0 µg/L 1 10/20/2020 7:16:59 PM

Lab SampleID: 201013039-047 **Collection Date:** 10/7/2020
Client Sample ID: ES-405-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE **Analyst: FLD**
Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-048 **Collection Date:** 10/7/2020
Client Sample ID: ES-405-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 10/13/2020)
Lead **1.7** 1.0 µg/L 1 10/20/2020 7:20:43 PM

Lab SampleID: 201013039-049 **Collection Date:** 10/7/2020
Client Sample ID: ES-406-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE **Analyst: FLD**
Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-050 **Collection Date:** 10/7/2020
Client Sample ID: ES-406-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 10/13/2020)
Lead **ND** 1.0 µg/L 1 10/20/2020 7:24:26 PM

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-051 **Collection Date:** 10/7/2020
Client Sample ID: ES-407-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-052 **Collection Date:** 10/7/2020
Client Sample ID: ES-407-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 7:28:10 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-053 **Collection Date:** 10/7/2020
Client Sample ID: ES-4GP-F1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-054 **Collection Date:** 10/7/2020
Client Sample ID: ES-4GP-F2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-055 **Collection Date:** 10/7/2020
Client Sample ID: ES-502-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-056 **Collection Date:** 10/7/2020
Client Sample ID: ES-502-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 7:39:25 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-057 **Collection Date:** 10/7/2020
Client Sample ID: ES-503-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-058 **Collection Date:** 10/7/2020
Client Sample ID: ES-503-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 7:43:10 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-059 **Collection Date:** 10/7/2020
Client Sample ID: ES-504-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-060 **Collection Date:** 10/7/2020
Client Sample ID: ES-504-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 7:46:55 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-061 **Collection Date:** 10/7/2020
Client Sample ID: ES-505-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-062 **Collection Date:** 10/7/2020
Client Sample ID: ES-505-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 7:50:39 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-063 **Collection Date:** 10/7/2020
Client Sample ID: ES-506-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-064 **Collection Date:** 10/7/2020
Client Sample ID: ES-506-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 8:09:17 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-065 **Collection Date:** 10/7/2020
Client Sample ID: ES-507-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-066 **Collection Date:** 10/7/2020
Client Sample ID: ES-507-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 8:13:00 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-067 **Collection Date:** 10/7/2020
Client Sample ID: ES-5GP-F1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-068 **Collection Date:** 10/7/2020
Client Sample ID: ES-5GP-F2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-069 **Collection Date:** 10/7/2020
Client Sample ID: ES-A41-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-070 **Collection Date:** 10/7/2020
Client Sample ID: ES-A41-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 8:16:44 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-071 **Collection Date:** 10/7/2020
Client Sample ID: ES-C-F1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-072 **Collection Date:** 10/7/2020
Client Sample ID: ES-C-F2 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-081 **Collection Date:** 10/7/2020
Client Sample ID: ES-K1-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Lab SampleID: 201013039-082 **Collection Date:** 10/7/2020
Client Sample ID: ES-K1-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 8:27:57 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-083 **Collection Date:** 10/7/2020
Client Sample ID: ES-K2-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService			NA		10/7/2020
-------------	--------------	--	--	----	--	-----------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-084 **Collection Date:** 10/7/2020
Client Sample ID: ES-K2-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 10/13/2020)
Lead **ND** 1.0 µg/L 1 10/20/2020 8:31:43 PM

Lab SampleID: 201013039-085 **Collection Date:** 10/7/2020
Client Sample ID: ES-K3-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE **Analyst: FLD**
Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-086 **Collection Date:** 10/7/2020
Client Sample ID: ES-K3-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 10/13/2020)
Lead **ND** 1.0 µg/L 1 10/20/2020 8:35:28 PM

Lab SampleID: 201013039-087 **Collection Date:** 10/7/2020
Client Sample ID: ES-K4-F **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE **Analyst: FLD**
Observation **OutofService** NA 10/7/2020

Lab SampleID: 201013039-088 **Collection Date:** 10/7/2020
Client Sample ID: ES-K4-S **Matrix:** DRINKING WATER

Analyses **Result** **RL** **Qual** **Units** **DF** **Date Analyzed**

ICP/MS - EPA 200.8 REV 5.4 **Analyst: SM**
(**Prep:** - 10/13/2020)
Lead **ND** 1.0 µg/L 1 10/20/2020 8:46:41 PM

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-089 **Collection Date:** 10/7/2020
Client Sample ID: ES-K5-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService	NA				10/7/2020
-------------	--------------	----	--	--	--	-----------

Lab SampleID: 201013039-090 **Collection Date:** 10/7/2020
Client Sample ID: ES-K5-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 8:50:25 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-091 **Collection Date:** 10/7/2020
Client Sample ID: ES-K6-F **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE Analyst: FLD

Observation	OutofService	NA				10/7/2020
-------------	--------------	----	--	--	--	-----------

Lab SampleID: 201013039-092 **Collection Date:** 10/7/2020
Client Sample ID: ES-K6-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 8:54:09 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-093 **Collection Date:** 10/7/2020
Client Sample ID: ES-KS-3 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	41.6	1.0	X	µg/L	1	10/20/2020 9:05:21 PM
------	------	-----	---	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 06-Nov-20

CLIENT: Mechanicville City School District
Project: Elementary School

LabWork Order: 201013039
PO#:

Lab SampleID: 201013039-094 **Collection Date:** 10/7/2020
Client Sample ID: ES-KS-4 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	1.4	1.0		µg/L	1	10/20/2020 9:09:05 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-095 **Collection Date:** 10/7/2020
Client Sample ID: ES-MC-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 9:12:49 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-096 **Collection Date:** 10/7/2020
Client Sample ID: ES-MO-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 9:31:31 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-097 **Collection Date:** 10/7/2020
Client Sample ID: ES-NO-S1 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 9:35:16 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 201013039-098 **Collection Date:** 10/7/2020
Client Sample ID: ES-TR-S **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
 (Prep: - 10/13/2020)

Lead	ND	1.0		µg/L	1	10/20/2020 9:39:02 PM
------	----	-----	--	------	---	-----------------------



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201013039
 COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns


Mechanicville CSD Address: _____
 Send Report to: _____ Project Name (Location): **Elementary School** Samplers Name: Ryan Baisley / Charles Haaker
 Client Phone #: _____ Client PO #: _____ Samplers Signature: [Signature]
 Client Email: _____

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	ES-101-F	10/7/2010	0625	PW		X	10	0	Lead OBS: out of Service
002	ES-101-S		0625	PW		X	1	0	Lead
003	ES-102-F		0626	PW		X	10	0	Lead OBS: out of Service
004	ES-102-S		0626	PW		X	1	0	Lead
005	ES-103-F		0627	PW		X	10	0	Lead OBS: out of Service
006	ES-103-S		0627	PW		X	1	0	Lead
007	ES-104-F		0628	PW		X	10	0	Lead OBS: out of Service
008	ES-104-S		0628	PW		X	1	0	Lead
009	ES-105-F		0629	PW		X	10	0	Lead OBS: out of Service
010	ES-105-S		0629	PW		X	1	0	Lead
011	ES-106-F		0629	PW		X	10	0	Lead OBS: out of Service
012	ES-106-S		0629	PW		X	1	0	Lead
013	ES-16P-F1		0630	PW		X	10	0	Lead OBS: out of Service
014	ES-16P-F2		0630	PW		X	10	0	Lead OBS: out of Service
015	ES-201-F		0642	PW		X	10	0	Lead OBS: out of Service
016	ES-201-S		0642	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other: _____ Special Instructions/Remarks: _____
 Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard
 NOTE: Samples received after 3:30pm are considered next business day.

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature) <u>[Signature]</u>	Received by: (Signature) _____	Date _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Time _____
Relinquished by: (Signature) _____	Received for Laboratory by: <u>[Signature]</u>	Date <u>10/13/10</u>	Time <u>11:00am</u>

Sample Temperature Ambient Notes: Ice preservation not required Bottles AES: <u>Y</u> / N	Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaO 4=Na ₂ S ₂ O ₃ 9=NaOH pH: 10=Other _____	Received Within Holding Times: <u>Y</u> / N Notes:  201013039
---	---	--



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 2010130351

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Mechanicville CSD		Address:							
Send Report to:		Project Name (Location): Elementary School			Samplers Name: Ryan Baisley/Charles Hacker				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	ES-202-F	10/7/2020	0642	PW		X	10	0	Lead OBS: out of Service
018	ES-202-S		0642	PW		X	1	0	Lead
019	ES-203-F		0641	PW		X	10	0	Lead OBS: out of Service
020	ES-203-S		0641	PW		X	1	0	Lead
021	ES-204-F		0641	PW		X	10	0	Lead OBS: out of Service
022	ES-204-S		0641	PW		X	1	0	Lead
023	ES-205-F		0640	PW		X	10	0	Lead Obs: Out of Service
024	ES-205-S		0640	PW		X	1	0	Lead
025	ES-206-F		0640	PW		X	10	0	Lead OBS: out of Service
026	ES-206-S		0640	PW		X	1	0	Lead
027	ES-26P-F1		0645	PW		X	10	0	Lead OBS: out of Service
028	ES-26P-F2		0645	PW		X	10	0	Lead OBS: out of Service
029	ES-301-F		0637	PW		X	10	0	Lead OBS: out of Service
030	ES-301-S		0637	PW		X	1	0	Lead
031	ES-302-F		0637	PW		X	10	0	Lead OBS: out of Service
032	ES-302-S		0637	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

PLEASE FILL ALL PINK SHADED AREAS

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>[Signature]</i>	Date 10/13/20	Time 11:17am

Sample Temperature Ambient Notes: Ice preservation not required Bottles AES: Y / N	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
--	---	---



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201013039
COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Mechanicville CSD		Address:									
Send Report to:		Project Name (Location): Elementary School				Samplers Name: Ryan Bawley / Charles Hackett					
Client Phone #:		Client PO #:				Samplers Signature: 					
Client Email:											
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis		
				Matrix	C	G					
033	ES-303-F	10/7/20	0638	PW		X	10	0	Lead OBS: out of service		
034	ES-303-S		0638	PW		X	1	0	Lead		
035	ES-304-F		0638	PW		X	10	0	Lead OBS: out of service		
036	ES-304-S		0638	PW		X	1	0	Lead		
037	ES-305-F		0639	PW		X	10	0	Lead OBS: out of service		
038	ES-305-S		0639	PW		X	1	0	Lead		
039	ES-306-F		0639	PW		X	10	0	Lead OBS: out of service		
040	ES-306-S		0639	PW		X	1	0	Lead		
041	ES-402-F		0703	PW		X	10	0	Lead OBS: out of service		
042	ES-402-S		0703	PW		X	1	0	Lead		
043	ES-403-F		0703	PW		X	10	0	Lead OBS: out of service		
044	ES-403-S		0703	PW		X	1	0	Lead		
045	ES-404-F		0701	PW		X	10	0	Lead OBS: out of service		
046	ES-404-S		0701	PW		X	1	0	Lead		
047	ES-405-F		0701	PW		X	10	0	Lead OBS: out of service		
048	ES-405-S		0701	PW		X	1	0	Lead		

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard					
NOTE: Samples received after 3:30pm are considered next business day.					

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃	5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
	Bottles AES: Y / N		



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201013039

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Mechanicville CSD		Address:	
Send Report to:		Project Name (Location): Elementary School	Samplers Name: <i>Ryan Baibley / Charles Hickey</i>
Client Phone #:		Client PO #:	Samplers Signature: <i>[Signature]</i>
Client Email:			

AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
049	ES-406-F	10/7/20	0700	PW		X	0	0	Lead OBS: out of Service
050	ES-406-S		0700	PW		X	1	0	Lead
051	ES-407-F		0701	PW		X	0	0	Lead OBS: out of Service
052	ES-407-S		0701	PW		X	1	0	Lead
053	ES-46P-F1		0702	PW		X	0	0	Lead OBS: out of Service
054	ES-46P-F2		0702	PW		X	0	0	Lead OBS: out of Service
055	ES-502-F		0645	PW		X	0	0	Lead OBS: out of Service
056	ES-502-S		0645	PW		X	1	0	Lead
057	ES-503-F		0645	PW		X	0	0	Lead OBS: out of Service
058	ES-503-S		0645	PW		X	1	0	Lead
059	ES-504-F		0646	PW		X	0	0	Lead OBS: out of Service
060	ES-504-S		0646	PW		X	1	0	Lead
061	ES-505-F		0646	PW		X	0	0	Lead OBS: out of Service
062	ES-505-S		0646	PW		X	1	0	Lead
063	ES-506-F		0646	PW		X	0	0	Lead OBS: out of Service
064	ES-506-S		0646	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:	Special Instructions/Remarks:
--	-------------------------------

Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard	PLEASE FILL ALL PINK SHADED AREAS
--	-----------------------------------

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature) <i>[Signature]</i>	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by: <i>[Signature]</i>	Date	Time

Sample Temperature Ambient Notes: Ice preservation not required Bottles AES: Y / N	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
---	---	---



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 201013039

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Mechanicville CSD		Address:									
Send Report to:		Project Name (Location): Elementary School			Samplers Name: <i>Ryan Bairstey/Charles Hacker</i>						
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>						
Client Email:											
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis		
				Matrix	C	G					
065	ES-507-F	10/7/20	0647	PW		X	10	0	Lead OBS: out of Service		
066	ES-507-S		0647	PW		X	1	0	Lead		
067	ES-56P-F1		0648	PW		X	10	0	Lead OBS: out of Service		
068	ES-56P-F2		0648	PW		X	10	0	Lead OBS: out of Service		
069	ES-A41-F		0710	PW		X	10	0	Lead OBS: out of Service		
070	ES-A41-S		0710	PW		X	1	0	Lead		
071	ES-C-F1		0612	PW		X	10	0	Lead OBS: out of Service		
072	ES-C-F2		0612	PW		X	10	0	Lead OBS: out of Service		
073	ES-CH-F1		0618	PW		X	10	0	Lead		
074	ES-CHall-F1		0618	PW		X	10	0	Lead		
075	ES-CH-F2		0618	PW		X	10	0	Lead		
076	ES-CHall-F2		0618	PW		X	10	0	Lead		
077	ES-G-F1		0620	PW		X	10	0	Lead		
078	ES-G-F2		0620	PW		X	10	0	Lead		
079	ES-G-F3		0620	PW		X	10	0	Lead		
080	ES-G-F4	✓	0620	PW		X	10	0	Lead ✓		
Shipment Arrived Via: FedEx UPS Client AES Other:				Special Instructions/Remarks:							
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS							
NOTE: Samples received after 3:30pm are considered next business day.											
Relinquished by: (Signature) <i>[Signature]</i>				Received by: (Signature)			Date	Time			
Relinquished by: (Signature)				Received by: (Signature)			Date	Time			
Relinquished by: (Signature)				Received for Laboratory by:			Date	Time			
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____				Received Within Holding Times: Y / N Notes:			
Bottles AES: Y / N											



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 201013039

COC Reference: 1378

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Mechanicville CSD		Address:									
Send Report to:		Project Name (Location): Elementary School				Samplers Name: Ryan Baisley / Charles Hacker					
Client Phone #:		Client PO #:				Samplers Signature:					
Client Email:											
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis		
				Matrix	C	G					
081	ES-K1-F	10/7/20	0635	PW		X	1	0	Lead OBS: out of Service		
082	ES-K1-S		0635	PW		X	1	0	Lead		
083	ES-K2-F		0634	PW		X	1	0	Lead OBS: out of Service		
084	ES-K2-S		0634	PW		X	1	0	Lead		
085	ES-K3-F		0633	PW		X	1	0	Lead OBS: out of Service		
086	ES-K3-S		0633	PW		X	1	0	Lead		
087	ES-K4-F		0633	PW		X	1	0	Lead OBS: out of Service		
088	ES-K4-S		0633	PW		X	1	0	Lead		
089	ES-K5-F		0632	PW		X	1	0	Lead OBS: out of Service		
090	ES-K5-S		0632	PW		X	1	0	Lead		
091	ES-K6-F		0630	PW		X	1	0	Lead OBS: out of Service		
092	ES-K6-S		0630	PW		X	1	0	Lead		
093	ES-K5-3		0610	PW		X	1	0	Lead		
094	ES-K5-4		0610	PW		X	1	0	Lead		
095	ES-MC-S		0622	PW		X	1	0	Lead		
096	ES-MD-S		0614	PW		X	1	0	Lead		

Shipment Arrived Via: FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested:
 1 Day 2 Day 3 Day 5 Day Standard

PLEASE FILL ALL PINK SHADED AREAS

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)
 Relinquished by: (Signature)
 Relinquished by: (Signature)

Received by: (Signature)	Date	Time
Received by: (Signature)	Date	Time
Received for Laboratory by:	Date	Time

Sample Temperature
 Ambient
 Notes: Ice preservation not required
 Bottles AES: Y / N

Properly Preserved: Y / N
 0=None 5=NH₄Cl
 1=H₂SO₄ pH<2 6=Ascorbic Acid
 2=HNO₃ pH<2 7=FAS
 3=HCl pH<2 8=ZnAc/NaOH pH>9
 4=Na₂S₂O₃ 9=NaOH pH>10
 10=Other

Received Within Holding Times: Y / N
 Notes:



314 North Pearl Street
 Albany, NY 12207
 518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#: 201013039

COC Reference: 1378

A full service analytical research laboratory offering solutions to environmental concerns

Mechanicville CSD		Address:							
Send Report to:		Project Name (Location): Elementary School			Samplers Name: <i>Ryan Baisley / Charles Hacker</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
097	ES-NO-S1	10/7/20	0617	PW		X	1	0	Lead
098	ES-TR-S	10/7/20	0619	PW		X	1	0	Lead
099	ES-			PW		X	1	0	Lead
100	ES-			PW		X	1	0	Lead
101	ES-			PW		X	1	0	Lead
102	ES-			PW		X	1	0	Lead
103	ES-			PW		X	1	0	Lead
104	ES-			PW		X	1	0	Lead
105	ES-			PW		X	1	0	Lead
106	ES-			PW		X	1	0	Lead
107	ES-			PW		X	1	0	Lead
108	ES-			PW		X	1	0	Lead
109	ES-			PW		X	1	0	Lead
110	ES-			PW		X	1	0	Lead
111	ES-			PW		X	1	0	Lead
112	ES-			PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client AES Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				PLEASE FILL ALL PINK SHADED AREAS					
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature) <i>[Signature]</i>				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received by: (Signature)			Date	Time	
Relinquished by: (Signature)				Received for Laboratory by: <i>[Signature]</i>			Date 10/13/20 11:20 AM	Time	
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Received Within Holding Times: Y / N Notes:			
Bottles AES: Y / N									



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.