



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

May 04, 2021

Joe Manzer
Mechanicville City School District
25 Kniskern Ave
Mechanicville, NY 12118
TEL: (518) 664-5727

Work Order No: 210429068

RE:

Elementary School

Dear Joe Manzer:

Adirondack Environmental Services, Inc received 51 samples on 4/29/2021 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Mechanicville City School District**Date:** 04-May-21

Elementary School

Lab WorkOrder: 210429068

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted**The results relate only to the items tested. Information supplied by the client is assumed to be correct.**

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-001**Collection Date:** 4/28/2021**Client Sample ID:** ES-101-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 5:14:58 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-002**Collection Date:** 4/28/2021**Client Sample ID:** ES-102-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.7	1.0		µg/L	1	5/3/2021 5:26:09 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-003**Collection Date:** 4/28/2021**Client Sample ID:** ES-103-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 5:29:54 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-004**Collection Date:** 4/28/2021**Client Sample ID:** ES-104-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.2	1.0		µg/L	1	5/3/2021 5:33:38 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-005**Collection Date:** 4/28/2021**Client Sample ID:** ES-105-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 5:37:23 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-006**Collection Date:** 4/28/2021**Client Sample ID:** ES-106-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	6.4	1.0		µg/L	1	5/3/2021 5:41:08 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-007**Collection Date:** 4/28/2021**Client Sample ID:** ES-1GP-F1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 5:52:20 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-008**Collection Date:** 4/28/2021**Client Sample ID:** ES-1GP-F2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 5:56:06 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-009**Collection Date:** 4/28/2021**Client Sample ID:** ES-201-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 5:59:52 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-010**Collection Date:** 4/28/2021**Client Sample ID:** ES-202-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:03:34 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-011**Collection Date:** 4/28/2021**Client Sample ID:** ES-203-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:07:16 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-012**Collection Date:** 4/28/2021**Client Sample ID:** ES-204-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:18:24 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-013**Collection Date:** 4/28/2021**Client Sample ID:** ES-205-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:22:07 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-014**Collection Date:** 4/28/2021**Client Sample ID:** ES-206-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:25:51 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-015**Collection Date:** 4/28/2021**Client Sample ID:** ES-301-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:37:01 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-016**Collection Date:** 4/28/2021**Client Sample ID:** ES-302-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:40:46 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-017**Collection Date:** 4/28/2021**Client Sample ID:** ES-303-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:44:30 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-018**Collection Date:** 4/28/2021**Client Sample ID:** ES-304-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:48:15 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-019**Collection Date:** 4/28/2021**Client Sample ID:** ES-305-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	5.6	1.0		µg/L	1	5/3/2021 6:52:00 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-020**Collection Date:** 4/28/2021**Client Sample ID:** ES-306-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 6:55:42 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-021**Collection Date:** 4/28/2021**Client Sample ID:** ES-402-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.6	1.0		µg/L	1	5/3/2021 7:06:49 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-022**Collection Date:** 4/28/2021**Client Sample ID:** ES-403-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:25:26 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-023**Collection Date:** 4/28/2021**Client Sample ID:** ES-404-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:29:09 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-024**Collection Date:** 4/28/2021**Client Sample ID:** ES-405-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:32:54 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-025**Collection Date:** 4/28/2021**Client Sample ID:** ES-406-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:36:38 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-026**Collection Date:** 4/28/2021**Client Sample ID:** ES-407-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	2.3	1.0		µg/L	1	5/3/2021 7:40:23 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-027**Collection Date:** 4/28/2021**Client Sample ID:** ES-502-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:44:08 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-028**Collection Date:** 4/28/2021**Client Sample ID:** ES-503-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.0	1.0		µg/L	1	5/3/2021 7:47:50 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-029**Collection Date:** 4/28/2021**Client Sample ID:** ES-504-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:51:33 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-030**Collection Date:** 4/28/2021**Client Sample ID:** ES-505-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 7:55:15 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-031**Collection Date:** 4/28/2021**Client Sample ID:** ES-506-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	13.8	1.0		µg/L	1	5/3/2021 8:06:24 PM
------	------	-----	--	------	---	---------------------

Lab SampleID: 210429068-032**Collection Date:** 4/28/2021**Client Sample ID:** ES-507-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.1	1.0		µg/L	1	5/3/2021 8:17:34 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-033**Collection Date:** 4/28/2021**Client Sample ID:** ES-5GP-F1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:21:18 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-034**Collection Date:** 4/28/2021**Client Sample ID:** ES-5GP-F2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:25:02 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-035**Collection Date:** 4/28/2021**Client Sample ID:** ES-A41-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:28:46 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-036**Collection Date:** 4/28/2021**Client Sample ID:** ES-C-F1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:32:31 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-037**Collection Date:** 4/28/2021**Client Sample ID:** ES-C-F2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:36:16 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-038**Collection Date:** 4/28/2021**Client Sample ID:** ES-CH-F1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:39:59 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-039**Collection Date:** 4/28/2021**Client Sample ID:** ES-CHALL-F1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:51:08 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-040**Collection Date:** 4/28/2021**Client Sample ID:** ES-CH-F2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 8:54:51 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-041**Collection Date:** 4/28/2021**Client Sample ID:** ES-CHALL-F2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:06:00 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-042**Collection Date:** 4/28/2021**Client Sample ID:** ES-G-F1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:17:12 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-043**Collection Date:** 4/28/2021**Client Sample ID:** ES-G-F2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:20:56 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-044**Collection Date:** 4/28/2021**Client Sample ID:** ES-G-F3**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:24:41 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-045**Collection Date:** 4/28/2021**Client Sample ID:** ES-G-F4**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:35:53 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order:** 210429068**Project:** Elementary School**PO#:****Lab SampleID:** 210429068-046**Collection Date:** 4/28/2021**Client Sample ID:** ES-K1-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:39:36 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-047**Collection Date:** 4/28/2021**Client Sample ID:** ES-K2-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:43:19 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-048**Collection Date:** 4/28/2021**Client Sample ID:** ES-K3-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:47:03 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 210429068-049**Collection Date:** 4/28/2021**Client Sample ID:** ES-K4-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.8	1.0		µg/L	1	5/3/2021 9:50:46 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 210429068-050**Collection Date:** 4/28/2021**Client Sample ID:** ES-K5-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	ND	1.0		µg/L	1	5/3/2021 9:54:30 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 04-May-21

CLIENT: Mechanicville City School District**LabWork Order: 210429068****Project:** Elementary School**PO#:****Lab SampleID:** 210429068-051**Collection Date:** 4/28/2021**Client Sample ID:** ES-K6-F**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 4/30/2021)

Lead	1.2	1.0		µg/L	1	5/3/2021 9:58:13 PM
------	-----	-----	--	------	---	---------------------



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210429068

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Mechanicville CSD		Address:							
Send Report to:		Project Name (Location) Elementary School				Samplers Name: <i>Jason Bortelle</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preser- vative	Analysis
				Matrix	C	G			
001	ES-101-F	4-28-21	6:45	PW		X	1	0	Lead
002	ES-102-F		6:46	PW		X	1	0	Lead
003	ES-103-F		6:47	PW		X	1	0	Lead
004	ES-104-F		6:48	PW		X	1	0	Lead
005	ES-105-F		6:49	PW		X	1	0	Lead
006	ES-106-F		6:50	PW		X	1	0	Lead
007	ES-1GP-F1		6:51	PW		X	1	0	Lead
008	ES-1GP-F2		6:52	PW		X	1	0	Lead
009	ES-201-F		7:04	PW		X	1	0	Lead
010	ES-202-F		7:05	PW		X	1	0	Lead
011	ES-203-F		7:06	PW		X	1	0	Lead
012	ES-204-F		7:07	PW		X	1	0	Lead
013	ES-205-F		7:08	PW		X	1	0	Lead
014	ES-206-F		7:09	PW		X	1	0	Lead
015	ES-301-F		7:00	PW		X	1	0	Lead
016	ES-302-F	✓	7:01	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
PLEASE FILL ALL PINK SHADED AREAS									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>[Signature]</i>				Date 4/29/21	Time 4:15pm
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Received Within Holding Times: <u>Y</u> / N Notes:	
Bottles AES: <u>Y</u> / N									



210429068



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210429068

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Mechanicville CSD		Address:							
Send Report to:		Project Name (Location) Elementary School				Samplers Name: <i>Jason Bartelle</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	ES-303-F	4-28-21	7:02	PW		X	1	0	Lead
018	ES-304-F		7:02	PW		X	1	0	Lead
019	ES-305-F		7:03	PW		X	1	0	Lead
020	ES-306-F		7:03	PW		X	1	0	Lead
021	ES-402-F		7:18	PW		X	1	0	Lead
022	ES-403-F		7:19	PW		X	1	0	Lead
023	ES-404-F		7:20	PW		X	1	0	Lead
024	ES-405-F		7:21	PW		X	1	0	Lead
025	ES-406-F		7:22	PW		X	1	0	Lead
026	ES-407-F		7:23	PW		X	1	0	Lead
027	ES-502-F		7:10	PW		X	1	0	Lead
028	ES-503-F		7:11	PW		X	1	0	Lead
029	ES-504-F		7:12	PW		X	1	0	Lead
030	ES-505-F		7:13	PW		X	1	0	Lead
031	ES-506-F		7:14	PW		X	1	0	Lead
032	ES-507-F		7:15	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>[Signature]</i>				Date 4/29/21	Time 4:15pm
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH> 10=Other				Received Within Holding Times: <u>Y</u> / N	
Bottles AES: <u>Y</u> / N								Notes:	



210429068



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210429068

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Mechanicville CSD		Address:							
Send Report to:		Project Name (Location) Elementary School				Samplers Name: <i>Jason Bottelle</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>J.B.</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	ES-5GP-F1	4-28-21	7:16	PW		X	1	0	Lead
034	ES-5GP-F2		7:16	PW		X	1	0	Lead
035	ES-A41-F		7:25	PW		X	1	0	Lead
036	ES-C-F1		6:35	PW		X	1	0	Lead
037	ES-C-F2		6:35	PW		X	1	0	Lead
038	ES-CH-F1		6:36	PW		X	1	0	Lead
039	ES-Chall-f1		6:39	PW		X	1	0	Lead
040	ES-CH-F2		6:36	PW		X	1	0	Lead
041	ES-Chall-F2		6:39	PW		X	1	0	Lead
042	ES-G-F1		6:56	PW		X	1	0	Lead
043	ES-G-F2		6:56	PW		X	1	0	Lead
044	ES-G-F3		6:51	PW		X	1	0	Lead
045	ES-G-F4		6:51	PW		X	1	0	Lead
046	ES-K1-F		6:42	PW		X	1	0	Lead
047	ES-K2-F		6:43	PW		X	1	0	Lead
048	ES-K3-F	✓	6:44	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature) _____									
Relinquished by: (Signature) _____				Received by: (Signature) _____				Date	Time
Relinquished by: (Signature) _____				Received by: (Signature) _____				Date	Time
Relinquished by: (Signature) <i>J.B.</i>				Received for Laboratory by: <i>Alcott</i>				Date 4/29/21	Time 4:15pm
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____				Received Within Holding Times: <u>Y</u> / N Notes:			
Bottles AES: <u>Y</u> / N									



210429068



14 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210429068

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Mechanicville CSD		Address:								
Send Report to:		Project Name (Location) Elementary School				Samplers Name: <i>Jason Bactelle</i>				
Client Phone #:		Client PO #:				Samplers Signature: <i>JB</i>				
Client Email:										
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preser- vative	Analysis	
				Matrix	C	G				
049	ES-K4-F	4-28-21	6:45	PW		X	1	0	Lead	
050	ES-K5-F		6:46	PW		X	1	0	Lead	
051	ES-K6-F		6:47	PW		X	1	0	Lead	
052				PW		X	1	0	Lead	
053				PW		X	1	0	Lead	
054				PW		X	1	0	Lead	
055				PW		X	1	0	Lead	
056				PW		X	1	0	Lead	
057				PW		X	1	0	Lead	
058				PW		X	1	0	Lead	
059				PW		X	1	0	Lead	
060				PW		X	1	0	Lead	
061				PW		X	1	0	Lead	
062				PW		X	1	0	Lead	
063				PW		X	1	0	Lead	
064				PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____				Special Instructions/Remarks:						
Turnaround Time Requested: ④ 1 Day ④ 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.										
				PLEASE FILL ALL PINK SHADED AREAS						
Relinquished by: (Signature)				Received by: (Signature)				Date	Time	
Relinquished by: (Signature)				Received by: (Signature)				Date	Time	
Relinquished by: (Signature) <i>JB</i>				Received for Laboratory by: <i>ACA</i>				Date 4/29/21	Time 4:15pm	
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____				Received Within Holding Times: <u>Y</u> / N Notes:		
Bottles AES: <u>Y</u> / N										



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.